



Addendum/Clarifications

REQUEST FOR PROPOSAL FOR THE PROVISION OF CONSULTANCY, PROJECT MANAGEMENT AND QUANTITY SURVEYING SERVICES ON CHILLED WATER PIPING SYSTEM AT THE BANK OF MAURITIUS TOWER BUILDING

We refer to the RFP for the “*provision of consultancy, project management and quantity surveying services on chilled water piping system at the Bank of Mauritius Tower Building*”, launched on 10 February 2026.

Following a query raised by potential bidders, the response of the Bank is as follows:

SN	Query from Bidders	Response
1	<p><u><i>Query on shutting down of chilled water system</i></u></p> <p>“Whether the BOM would be agreeable to complete shut-down of the chilled water system for several months (estimated to be about 5 months) during the winter months in particular, to enable the proposed chilled water pipe works.”</p>	<p>The Bank is aware of the challenges associated with this project. Unfortunately, the chillers cannot be turned off except during overnight and weekends to allow welding works and the connection of pipes to the chillers.</p>

Bank of Mauritius
26 February 2026